



CONTATORE
ENERGIA



AVANQUADRO

LINEA PRINCIPALE
CADUTA DI TENSIONE 1%



QUADRO
GENERALE

LINEA DERIVATA
CADUTA DI TENSIONE 3%



CARICO

MONOFASE (F-N) 230V

SEZIONI	(mm ²)	4	6	10	16	25	35	50	70	95	120	150
PVC o gomma G, G1	I _z (A)	36	46	63	85	110	137	167	213	258	299	344
Gomma G5, G7	I _z (A)	45	58	80	107	135	169	207	268	328	382	441
Potenza contrat. (kW)	I _B (A)	I _n Interrutt. (A)	Lunghezza massima (m)									
3	* 15 (17)	20	13	19	32	51	81	112	152	-	-	-
6	* 32 (35)	40	6	9	15	24	38	52	71	103	142	-
10	* 50 (56)	63	/	/	10	15	24	34	46	66	91	115