



CONTATORE  
ENERGIA



AVANQUADRO

LINEA PRINCIPALE  
CADUTA DI TENSIONE 1%



QUADRO  
GENERALE

LINEA DERIVATA  
CADUTA DI TENSIONE 3%



CARICO

TRIFASE (3F-N) 400V

SEZIONI		(mm <sup>2</sup> )	4	6	10	16	25	35	50	70	95	120	150
PVC o gomma G, G1		I <sub>2</sub> (A)	29	37	50	68	88	110	134	170	206	239	275
Gomma G5, G7		I <sub>2</sub> (A)	36	46	64	86	108	135	166	214	262	306	353
Potenza contrattuale (kW)	I <sub>B</sub> (A)	I <sub>n</sub> Interruttore (A)	Lunghezza massima (m)										
6	* 11 (12)	16	35	53	88	139	220	-	-	-	-	-	-
10	* 17 (19)	20	23	34	57	91	143	199	268	-	-	-	-
15	* 25 (28)	32	15	23	38	60	95	133	179	259	-	-	-
20	* 33 (37)	40	/	18	29	46	73	102	137	199	275	-	-
25	* 41 (46)	50	/	/	24	37	59	82	111	160	221	279	341
30	* 50 (56)	63	/	/	19	31	48	67	91	131	181	229	279
35	63	63	/	/	15	24	38	53	72	104	144	182	222
40	80	80	/	/	/	19	30	42	57	82	113	143	175
45	80	80	/	/	/	19	30	42	57	82	113	143	175
50	100	100	/	/	/	/	24	34	45	66	91	114	140
55	100	100	/	/	/	/	24	34	45	66	91	114	140
60	125	125	/	/	/	/	/	27	36	53	73	92	112
70	125	125	/	/	/	/	/	27	36	53	73	92	112