



CONTATORE
ENERGIA



AVANQUADRO

LINEA PRINCIPALE
CADUTA DI TENSIONE 1%



QUADRO
GENERALE

LINEA DERIVATA
CADUTA DI TENSIONE 3%



CARICO

TRIFASE (3F-N) 400V

SEZIONE		(mm ²)	1,5	2,5	4	6	10	16	25	35	50	70	95	120	150
PVC o gomma G, G1		I ₂ (A)	15,5	21,5	29	37	50	68	88	110	134	170	206	239	275
Gomma G5, G7		I ₂ (A)	19	26	36	46	64	86	108	135	166	214	262	306	353
I _n Presa (A)	I _n Interruttore (A)	I _n Fusibile (A)	Lunghezza massima (m)												
		2	218	363	-	-	-	-	-	-	-	-	-	-	-
		4	109	182	-	-	-	-	-	-	-	-	-	-	-
	6		73	121	193	-	-	-	-	-	-	-	-	-	-
		6	73	121	-	-	-	-	-	-	-	-	-	-	-
		8	55	91	-	-	-	-	-	-	-	-	-	-	-
	10		44	73	116	174	289	-	-	-	-	-	-	-	-
		10	44	73	-	-	-	-	-	-	-	-	-	-	-
		12	36	61	-	-	-	-	-	-	-	-	-	-	-
	16		27	45	72	109	181	287	-	-	-	-	-	-	-
16		16	/	45	-	-	-	-	-	-	-	-	-	-	-
	20		/	36	58	87	145	230	363	504	680	-	-	-	-
		20	/	36	58	87	-	-	-	-	-	-	-	-	-
	25		/	29	46	70	116	184	290	404	544	788	1088	-	-
		25	/	/	46	70	-	-	-	-	-	-	-	-	-
	32		/	/	36	54	90	144	227	315	425	615	850	-	-
32		32	/	/	36	54	-	-	-	-	-	-	-	-	-
	40		/	/	/	44	72	115	182	252	340	492	680	858	1048
		40	/	/	/	44	72	-	-	-	-	-	-	-	-
	50		/	/	/	/	58	92	145	202	272	394	544	687	838
		50	/	/	/	/	58	-	-	-	-	-	-	-	-
63	63		/	/	/	/	46	73	115	160	216	313	432	545	665
		50	/	/	/	/	58	92	145	202	-	-	-	-	-
	63		/	/	/	/	73	115	160	-	-	-	-	-	-
	80		/	/	/	/	/	57	91	126	170	246	340	429	524
		80	/	/	/	/	/	91	126	-	-	-	-	-	-
	100		/	/	/	/	/	73	*95	*109	197	272	343	419	-
		100	/	/	/	/	/	/	*95	-	-	-	-	-	-
125	125		/	/	/	/	/	/	*76	*87	158	218	275	335	-